



# Quality Assurance Report lecc Blower Door Test

<b>FAIL</b>	<b>Your Result: 22.21 ACH50 (5292.40 CFM50 * 60 / 14300 ft³) Target &lt; 3 ACH50</b>
-------------	--

## Test Information

Test Name	Home first test
Test Date	2022-03-21 04:28 PM (UTC-4)
Export id	02FNNGFB
Company Name	A.D. Home Inspections LLC
Technician Name	Ammon Hontz
Technician Email	adhomes@ptd.net

## Building Information

Address	131 Center Avenue
City	Jim Thorpe
State	PA
Zip/postal Code	18229
Country	United States
Year Constructed	1900
Elevation	784 ft
Address Verified?	No
Building Latitude, Longitude	Your location has not been validated.
GPS validation	<a href="#">Latitude/Longitude: 40.866748, -75.739920; Accuracy: 335 ft</a>
Estimated Distance From Address	Not available

## Test Equipment

Fan Model	Retrotec 5000
Fan Serial Number	SFN103856
Pressure Gauge Model	Retrotec DM32 10A
Gauge Serial Number	414452

## Environmental Conditions

Pre-test Indoor Temperature	66 °F
Pre-test Outdoor Temperature	60 °F
Wind Speed	5 MPH
Average Barometric Pressure	102 kPa

## Test Dimensions

Conditioned Floor Area	1100 ft²
Volume	14300 ft³



### Test Results Summary

Test Type	lecc Blower Door Test
Flow Reference Pressure	50 Pa
Time Averaging	10 seconds
Induced House Pressure (includes baseline)	-49.33 Pa
Nominal Fan Flow	5292.4 CFM @ 50 Pa
Corrected Flow	5292.4 CFM @ 50 Pa
Air Changes Per Hour	22.206

### Test Results

#### Test Data Set 1

Flow Direction	Depressurize
Gauge Location	Inside

#### Baseline Pressure, Initial (Pa)

0.1	0.1	0.1	0	0	-0.2	-0.2	-0.1	0	0.1
-----	-----	-----	---	---	------	------	------	---	-----

Baseline Duration	11 seconds
Average baseline	-0.01 Pa

Measured Pressure (Pa)	-49.34
Fan Pressure [5000 - Open] (Pa)	93.33
Flow (CFM)	5246.19



### Test Notes

No notes entered.

### Flow Equation Parameters - Factory Default

Fan Model Retrotec 5000

Fan Serial Number SFN103856

#### Flow equation parameters - B1

Units Used For Flow Parameters in Equation CFM

Fan pressure (FP) is the measured fan pressure when using a self-referenced fan or when the room pressure is negative. If using a fan which is not self-referenced, and the room pressure is positive, fan pressure is calculated by subtracting the measured room pressure from the absolute value of the fan pressure.

If PrA is greater than 0 or fan is self-referencing:  $FP = |PrB| - PrA$

If PrA is less than 0 or fan is self-referencing:  $FP = PrB$

Flow calculations are not valid if fan pressure is less than either MF or  $(K2 \times |RP|)$

FP = fan pressure, RP = room pressure

Range	N	K	K1	K2	K3	K4	MF
Open	0.4980	548.0000	0.0000	0.3000	0.0000	1	10
A	0.5020	287.0000	0.0000	0.4000	0.0000	1	20
B8	0.5400	113.2500	0.0000	0.7000	0.0000	1	40

$flow = (FP - RP \times K1)^n \times (K + K3 \times FP) \times K4$

Range	A	B	C	D	F	G	K2	MF
B4	0.0000079426	-0.00864000	4.9000	206.00	-0.19	29	0.8000	40
B2	0.0000008800	-0.00290000	2.1500	90.00	0.10	30	1.0000	50
B1	0.0000005000	-0.00128000	1.0200	54.00	0.00	30	1.0000	60
B74	0.0000007960	-0.00095010	0.5900	18.00	0.15	25	0.8000	35
B47	0.0000002690	-0.00035905	0.2435	12.05	0.09	25	1.0000	50
B29	0.0000001110	-0.00014900	0.0920	4.40	-0.02	25	0.6000	50

$flow = (A \times FP^3) + (B \times FP^2) + (C \times FP) + D + ((G - RP) \times F)$